

**PERMIT**  
**ON-SITE SEWAGE DISPOSAL SYSTEM**

Coordinates: N 39 23 5 W 78 47 27

Owner: Marcellna & Carlito Pascual Installer: Walter Fields  
Address: 7908 Well Water Way Address: HC 86 Box 35A  
Elkridge, MD 21075 Greenspring, WV 26722

You are hereby issued a permit to:  install  modify an on-site sewage disposal system located:  
Bluffs on the Potomac lot 225

Facility: Residence Design Flow: 3 Lot Size (ft<sup>2</sup>/acres): 20 acres Water Source: well

Based upon review of the information on your submitted application, dated 7/17/2018, and the proper installation of the herein described system, the system shall be in compliance with applicable West Virginia Sewage System Rules and Design Standards.

The sewage system shall consist of a:

- Septic tank - Capacity: 1000 gallons or more. Constructed of: Concrete or Plastic.
- Soil disposal system with a minimum equivalency of 900 square feet of conventional gravel trench area.

Depth to the bottom of the trench or bed installation shall be 24 inches from original ground surface.

Gravel system: Lengths of lines: \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_ feet. Width: \_\_\_\_\_ inches.

Chamber system: Number of lines: 3. Lengths of lines: 60's, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_.

Manufacturer of chamber: Bio.

Bed system:  Gravel  Chamber Length: \_\_\_\_\_ feet. Width \_\_\_\_\_ feet.

Other: \_\_\_\_\_

This permit is non-transferable and automatically expires 12 months after issue date.

This permit is NULL and VOID when official inspection reveals conditions different than those stipulated on the permit or facts are later found that would indicate non-compliance with applicable rules.

All systems must be inspected and approved prior to being covered with earth or placed into use.

The applicant or his agent must notify this department 72 hours or more prior to planned inspection time. Health Department Phone Number: 304-496-9641

**Additional Specifications**  
**on Reverse.**

Issue Date: 7/25/2018

Sanitarian: [Signature]

**Sketch of system**

