

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Hampshire County Health Department Installation Permit No. 57-14-26-241

Name of Owner WHITE, EDWARD A.

Address ALEXANDRIA, VA.

Property Address VALLEY VIEW SUB-DIVISION - LOT NO. 4

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served COTTAGE No. Water Closets 1

Lot Size 5 1/2 ACRES sq. ft. Area suitable for sewage disposal installation 10,000 sq. ft.

Source of Water Supply DRILLED WELL No. Lavatories 1

No. Bedrooms 2 No. Showers or Tubs 1 No. Baths 1

No. Garbage Grinders 0 No. Automatic Washers 1

SEPTIC TANK

Material CONCRETE Length x Width x Depth = cubic feet

Liquid Depth ft. Liquid Capacity 1,000 gal.

Distance to: Dwelling 15' Water Supply 70' Nearest Property Line 250'

SOIL ABSORPTION SYSTEM

Type Drain Line Material PLASTIC Trench Width 24 Inches

Trench Depth 30 Inches Total Absorption area in Trench Bottom sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media GRAVEL

No. of Drain Lines 4 Depth Filter Media Under Drain Line 6 Inches

Length of Each Line 40', 40', 60', 60' ft. Depth Filter Media Over Drain Line 2 in

Distance of Disposal Field to: (a) Dwelling 80'

(b) Water Supply 100' (c) Nearest Property Line 200

An inspection of the septic tank system described herein disclosed that said system (MEETS, ~~DOES NOT MEET~~) the minimum standards established by the West Virginia State Department of Health.

MAR. 11, 1977
Date

[Signature]
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

