

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Hampshire Health Department Installation Permit No. ST-1487025

Name of Owner Shirley Hicks

Address Ritter's Hidden Valley Lot # 4 Sec. 8

Property Address Ritter's Hidden Valley Subdivision Dillo's Run Pool

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served House No. Water Closets _____

Lot Size _____ sq. ft. Area suitable for sewage disposal installation _____ sq. ft.

Source of Water Supply Cistern No. Lavatories _____

No. Bedrooms 2 No. Showers or Tubs _____ No. Baths _____

No. Garbage Grinders no No. Automatic Washers ✓

* precast concrete Jolin SEPTIC TANK
Material _____ Length _____ x Width _____ x Depth _____ = _____ cubic feet

Liquid Depth _____ ft. Liquid Capacity 1000 gal.

Distance to: Dwelling _____ Water Supply _____ Nearest Property Line _____

* SOIL ABSORPTION SYSTEM

Type Drain Line Material plastic Trench Width 36 Inches

Trench Depth 26-28 Inches Total Absorption area in Trench Bottom 480 sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media gravel

No. of Drain Lines 2 Depth Filter Media Under Drain Line 6-8 Inches

Length of Each Line 80, 80, _____, _____ ft. Depth Filter Media Over Drain Line _____ in

Distance of Disposal Field to: (a) Dwelling _____

(b) Water Supply Cistern (c) Nearest Property Line _____
(not shown)

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

7-24-86
Date

David Dunlap R.S.
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

* Please refer to contractor's sketch attached to the final inspection form

HICKS
VALLEY

