

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM



Hampshire Health Department Installation Permit No. ST-14-93-024
Name of Owner M.A. "Mac" & Chris Young
Address Rt. 2 Box 535, Parkersville, VA 22123
Property Address Eco Deco I Lot #3

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served Home No. Water Closets _____
Lot Size 30 ^{acres} sq. ft. Area suitable for sewage disposal installation _____ sq. ft.
Source of Water Supply well No. Lavatories _____
No. Bedrooms 3 No. Showers or Tubs _____ No. Baths _____
No. Garbage Grinders _____ No. Automatic Washers _____

SEPTIC TANK

Material precast concrete Length _____ x Width _____ x Depth _____ = _____ cubic feet
Liquid Depth _____ ft. Liquid Capacity 1000 gal.
Distance to: Dwelling 40' Water Supply 60' Nearest Property Line 100'

SOIL ABSORPTION SYSTEM

Type Drain Line Material 2500 crush resistant Trench Width 36 Inches
Trench Depth 22-24 Inches Total Absorption area in Trench Bottom 1800 sq. ft.
Diameter of Drain Line 4 Inches Type Filter Media gravel - 90 ton
No. of Drain Lines 6 Depth Filter Media Under Drain Line 10 Inches
Length of Each Line 100, 100, 100, 100 ^{100', 100'} ft. Depth Filter Media Over Drain Line 2 in.
Distance of Disposal Field to: (a) Dwelling 70'
(b) Water Supply 150' (c) Nearest Property Line 100'

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

5-26-93
Date

David Dunlap RS
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

