

SS-183  
Rev 3/11



West Virginia Department of Health & Human Resources  
Hampshire County Health Department

Permit #: ST-14-23-100  
Tax District: Springfield  
Map # 24 Parcel # 34

# PERMIT ON-SITE SEWAGE DISPOSAL SYSTEM

Coordinates: N 39 26 4 W 78 44 19

Owner: Shawn Netzer Installer: Walter Fields  
Address: 17811 Oldtown Rd SE Address: 4565 Greenspring Rd  
Old Town, MD 21555 Greenspring, WV 26722

You are hereby issued a permit to:  install  modify an on-site sewage disposal system located:  
South Potomac Forest SD Lot 34

Facility: Residence Design Flow: 4 Lot Size (ft<sup>2</sup>/acres): 2.5 acres Water Source: \_\_\_\_\_

Based upon review of the information on your submitted application, dated 2/15/2023, and the proper installation of the herein described system, the system shall be in compliance with applicable West Virginia Sewage System Rules and Design Standards.

- The sewage system shall consist of a:
- Septic tank - Capacity: 1000 gallons or more. Constructed of: Concrete or Plastic.
  - Soil disposal system with a minimum equivalency of 1200 square feet of conventional gravel trench area.  
Depth to the bottom of the trench or bed installation shall be 24 inches from original ground surface.
  - Gravel system: Lengths of lines: \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_ feet. Width: \_\_\_\_\_ inches.
  - Chamber system: Number of lines: 3. Lengths of lines: 80', 80', 80', \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_.  
Manufacturer of chamber: Infiltrator.
  - Bed system:  Gravel  Chamber Length: \_\_\_\_\_ feet. Width \_\_\_\_\_ feet.
  - Other: \_\_\_\_\_

This permit is non-transferable and automatically expires 12 months after issue date.

This permit is NULL and VOID when official inspection reveals conditions different than those stipulated on the permit or facts are later found that would indicate non-compliance with applicable rules.

All systems must be inspected and approved prior to being covered with earth or placed into use.

The applicant or his agent must notify this department 72 hours or more prior to planned inspection time. Health Department Phone Number: 304-496-9641

**Additional Specifications  
on Reverse.**

Issue Date: 2/17/2023

Sanitarian:

