

**WV STATE DEPARTMENT OF HEALTH**  
Office of Environmental Health Services  
**ENVIRONMENTAL ENGINEERING DIVISION**

**WELL COMPLETION REPORT**

Date(s) July 17, 1995 County Hampshire Permit #: DW-1407-96-006  
 Town: Romney Area Name/Location South Patomac Forrest lot #8  
 Well Owner: Richard Zepp Address: 9502 HARMONY ROAD  
 Telephone Number: 301 371-5458 Meyersville, MD 21773  
 Well Driller: Jerry W Adams Address: P.O. Box 952  
 Telephone Number: 304 822-4092 Romney, WV 26757

**WELL LOG**

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
0-8'	Clay - UNCONSOLIDATED	Type of Well: <u>D/W</u> Drilling Method: <u>AIR ROTARY HAMMER</u>
8'	Clay & Shale - UNCONSOLIDATED	Well Diameter: <u>6"</u> Casing O.D.: <u>6-5/8"</u>
28'	SAND & GRAVEL - UNCONSOLIDATED	Well Depth: <u>160'</u> Date Completed: <u>JULY 17, 1995</u>
84'	limestone - Consolidated	CASING: Length <u>95</u> Feet Height above ground <u>1</u> Feet
94'	limestone - Consolidated	<input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Cast Iron
	Set CASING - GROUT	Other _____ Type _____
140'	limestone - Consolidated	<b>SCREEN</b> <input checked="" type="checkbox"/> None Installed Type _____ Diameter _____ Slot/Gauge _____ Length _____ Set Between _____ Ft. and _____ Ft.
156'	limestone - Consolidated	
	Water 6 GPM	
160'	limestone - Consolidated	
	Test Well yield - Stopped Drilling Operation	

**PUMPING OR BAILING TEST**

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>65' est</u>		
Pumping Rate (GPM)	<u>6</u>		
Pumping Level (Ft Below Grade)	<u>150</u>		
Duration of Test (In Hours)	<u>1/2</u>		
Recovery Time to Static Level (In Hours)	<u>1</u>		

**WELL HEAD**

Pitless Adapter: Type, Make, Etc. To be installed w/ Pump System  
 Well Cap: Type, Make, Etc. Royer 6-5/8" Conduit - Type  
 Well Seal: Type, Make, Etc. \_\_\_\_\_  
 Well Platform: \_\_\_\_\_  
 Length \_\_\_\_\_ Width \_\_\_\_\_ Thickness \_\_\_\_\_  
 Grouting:  Yes  No  
 All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

Jerry W Adams 004  
 Name A & S Well Drilling Certification No.  
 Registered Business Name  
Jerry W Adams July 17, 1995  
 Signed Date