

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Hampshire County Health Department Installation Permit No. ST. 14-85-274

Name of Owner Ivan D Dowdy

Address P.O. Box 328 Sh. As W.V. 26761

Property Address 1/2 mi in Golden Acres

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served Plastic/wood No. Water Closets _____

Lot Size 1/2 acre sq. ft. Area suitable for sewage disposal installation _____ sq. ft.

Source of Water Supply well No. Lavatories _____

No. Bedrooms 2 No. Showers or Tubs _____ No. Baths _____

No. Garbage Grinders NO No. Automatic Washers ✓

SEPTIC TANK

Material Concrete Length _____ x Width _____ x Depth _____ = _____ cubic feet

Liquid Depth _____ ft. Liquid Capacity 1000 gal.

Distance to: Dwelling 10 Water Supply 501 Nearest Property Line 15'

SOIL ABSORPTION SYSTEM

Type Drain Line Material plastic Trench Width 36 Inches

Trench Depth 28-30 Inches Total Absorption area in Trench Bottom 400 sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media gravel (1980)

No. of Drain Lines 2 Depth Filter Media Under Drain Line 6 Inches

Length of Each Line 70, 70, _____, _____ ft. Depth Filter Media Over Drain Line 2 in.

Distance of Disposal Field to: (a) Dwelling 10

(b) Water Supply 100+ (c) Nearest Property Line 12'

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

6-28-85
Date

David Dunlap RS
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.