

Rev 3/08 ST/CO USE ONLY DATE RECEIVED MM DD YY _____	DATE THE WELL WAS COMPLETED MM DD YY <u>06 02 16</u> PERMIT NO. DW- <u>14-16-068</u>	STATE OF WEST VIRGINIA WATER WELL COMPLETION REPORT	FORM SW-258 THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL IS COMPLETED FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE																													
LOCATION OF WELL Well Owner: Last Name <u>POORE, II</u> First Name <u>JACK</u> Street/Road <u>RT. 29 North</u> County <u>Harrison</u> Zip Code _____																																
Latitude: _____ Deg _____ Min _____ Sec Longitude: _____ Deg _____ Min _____ Sec Acquired By: <input type="checkbox"/> GPS <input type="checkbox"/> Topo <input type="checkbox"/> Other _____		AREA NAME/LOCATION: <u>Monument Hills sub.</u> <u>Lot 6</u>	TYPE OF WELL: <input checked="" type="checkbox"/> Potable <input type="checkbox"/> Public Water Supply <input type="checkbox"/> Geothermal <input type="checkbox"/> Industrial <input type="checkbox"/> Commercial <input type="checkbox"/> Dewatering <input type="checkbox"/> Irrigation <input type="checkbox"/> Test/Exploratory <input type="checkbox"/> Other _____																													
WELL LOG <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Depth</th> <th rowspan="2">State the kind of formation penetrated, their color, caves, and if water bearing with estimate flow (GPM).</th> </tr> <tr> <th>From (ft.)</th> <th>To (ft.)</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>9</td> <td>Brown + Red Sandstone (10 FT)</td> </tr> <tr> <td>9</td> <td>61</td> <td>Mostly Red / some Brown Hard Sandstone</td> </tr> <tr> <td>61</td> <td>100</td> <td>Red Sandstone</td> </tr> <tr> <td>100</td> <td>400</td> <td>Layers of Red + Blue + Gray Sandstone</td> </tr> <tr> <td>364</td> <td></td> <td>Water - 10 GPM</td> </tr> <tr> <td>377</td> <td></td> <td>Water - 10 GPM</td> </tr> <tr> <td colspan="3">Slightly Fractured A Few Rock Fragments</td> </tr> <tr> <td colspan="3"> If additional space is needed, use additional sheets and attach w/permit # at top. </td> </tr> </tbody> </table>		Depth		State the kind of formation penetrated, their color, caves, and if water bearing with estimate flow (GPM).	From (ft.)	To (ft.)	0	9	Brown + Red Sandstone (10 FT)	9	61	Mostly Red / some Brown Hard Sandstone	61	100	Red Sandstone	100	400	Layers of Red + Blue + Gray Sandstone	364		Water - 10 GPM	377		Water - 10 GPM	Slightly Fractured A Few Rock Fragments			If additional space is needed, use additional sheets and attach w/permit # at top.			DRILLING METHOD <input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Rotary Hammer <input type="checkbox"/> Other _____ Hole Diameter <u>6</u> (in) Total depth <u>400</u> (ft) CASINGS RECORD MAIN CASING TYPE <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <u>DRIVE SHOE</u> <input type="checkbox"/> Other _____ Casing Diameter <u>6 7/8</u> (in) Wall Thickness <u>.188</u> (in) Casing Length <u>80</u> (ft) Other Casing or Liner Used Type <input type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Other _____ Casing/Liner Diameter _____ (in) Length _____ (ft) from _____ (ft) to _____ (ft) SCREEN RECORD <input checked="" type="checkbox"/> Not Installed <input type="checkbox"/> Installed Material: <input type="checkbox"/> Bronze <input type="checkbox"/> Plastic Diameter of screen _____ (in) Slot size _____ Length _____ (ft) from _____ (ft) to _____ (ft) GRAVEL PACK RECORD Gravel Pack: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No From _____ (ft) to _____ (ft)	GROUTING RECORD Grouting Material: <input type="checkbox"/> Cement <input checked="" type="checkbox"/> Bentonite Clay Other _____ No. of Bags: <u>6</u> Installation Method: <u>PUMPED</u> PUMP INSTALLED By Driller <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ESTIMATED WELL YIELD Estimated at <u>20</u> G.P.M. Static Water Level <u>160</u> (ft) *Pumping level below land surface <u>398</u> (ft) after <u>1/2</u> hrs. at <u>20</u> G.P.M. (Estimated) *Note: For Public Water Supply wells please submit required yield and drawdown tests. WELL HEAD COMPLETION Casing height above grade <u>1</u> (ft) Type Of Well Cap _____ Installed: <u>Harvard</u> VARIANCE ISSUED <input type="checkbox"/> Yes <input type="checkbox"/> No Request Number _____ COMMENTS BY INSTALLER: <u>SET Pump Above 364"</u>
Depth		State the kind of formation penetrated, their color, caves, and if water bearing with estimate flow (GPM).																														
From (ft.)	To (ft.)																															
0	9	Brown + Red Sandstone (10 FT)																														
9	61	Mostly Red / some Brown Hard Sandstone																														
61	100	Red Sandstone																														
100	400	Layers of Red + Blue + Gray Sandstone																														
364		Water - 10 GPM																														
377		Water - 10 GPM																														
Slightly Fractured A Few Rock Fragments																																
If additional space is needed, use additional sheets and attach w/permit # at top.																																
I hereby certify that this well has been constructed in accordance with state rules and in conformance with all conditions stated in the above captioned permit, and that the information presented herein is accurate and complete to the best of my knowledge.																																
Company Name <u>B.W. Smith Well Drilling Inc.</u> WV Contractor No. <u>039905</u> Business Registration No. _____ Master Well Driller Certification No. <u>574</u> Master Well Driller (print) <u>Chris Wolford</u> Master Well Driller Signature <u>Chris Wolford</u>																																
SITE SUPERVISOR (SIGNATURE OF DRILLER OR JOURNEYMAN RESPONSIBLE FOR SITEWORK IF DIFFERENT FROM MASTER DRILLER.) Journeyman Well Driller Certification No. _____ Journeyman Well Driller (please print) _____ Apprentice and Name (s) _____																																

W - 884

B.W. SMITH WELL DRILLING INC.

Serving This Area Since 1957

COMPLETE WATER SYSTEMS**GOULDS • PUMPS**

Contractors Lic. WV038905

304-496-9977 • 304-822-4786

P.O. Box 440, Springfield, West Virginia 26763

Owner: Mark & Cindy Smith

SOLD TO:	<u>Jack Peore / J.P. Custom Homes</u>		
ADDRESS:	_____		
COUNTY	<u>Hampshire</u>	PHONE	<u>304-359-2530</u>
WELL PERMIT #	_____	DATE	<u>6-3-16</u>

TERMS: NET 10 DAYS

QTY.		DESCRIPTION	AMOUNT
400'	DRILLING		5000 00
80'	CASING	6" 1/8" O.D. steel 1/4"	1000 00
	LINER		
	GROUTING	Bentonite clay	350 00
1	CAP		50 00
1	DRIVE SHOE	6" steel weld-on	50 00
		Subtotal	6450 00
			- 450 00
	WATER FLOW	20 gpm at completion	
	WATER STORAGE		
		PAID IN FULL	
		Check # 3825	6-3-16
		Thank You!	

A SERVICE CHARGE OF 1-1/2% WILL BE ADDED TO ALL ACCOUNTS OVER 30 DAYS.

The above well casing pump, pipe equipment, etc., remains the property of Smith Well Drilling until paid in full and Smith Well Drilling shall have the right to go upon the premises without guilt of trespass and reclaim and recover any materials and equipment installed.

The purchaser agrees that it is responsible for attorney's fees and costs of any proceeding to enforce payment of any amounts.

B.W. Smith Well Drilling does not guarantee water quantity or quality.

TOTAL	6000 00
TOTAL	6000 00

White - Contractor Copy

Yellow - Return With Payment

Pink - Customer Copy